

# ADDENDUM NUMBER THREE

## SANTEE SCHOOL DISTRICT

**Bid #1920-001-077**

**Old Lockers/Shower Interior Demolition at Chet F. Harritt School Site**

DATE: June 13, 2019

General - All project documents including contract documents, drawings, and specifications, shall remain unchanged with the exception of those elements added, revised, deleted, or clarified by this addendum. **Acknowledge receipt of Addendum Number THREE in the appropriate place provided on the Bid Form**

ITEM NO. 1 ADDENDUM THREE	Clarifications
------------------------------	----------------

- A) Remove all concrete slabs and curbs within the entire area of work including terrazzo.
- B) Remove all Terrazzo in the area of work on floors, walls and showers.
- C) Remove all interior wall plaster and finishes, ceilings upper under structure and lower ceilings. Double ceilings in Shower/Locker: both are to be removed.
- D) Storage room and water heater Kiln room both have fire sprinkler heads from the old original wet pipe system tied to the domestic water supply only and like all other utilities shall be capped flush with surface of demolition.
- E) Electrical panel in wall to be demolished and removed in Boys locker room. It is fed from below back to building B electrical closet. Panel only supplies power lights and fans within the area of work and areas within the demolition area. Confirm with District. Panel can be removed after being de-energized/Turned off. Coordinate with District.
- F) Since the electrical sub panel in the boy's locker is to be removed, and the existing lights will not have a power source, Salvage all lights for District and turn over to District.
- G) Contractor responsible for appropriate temporary lighting in work areas for safe working conditions since the sub panel power in a demolished wall will be removed.

### END OF ADDENDUM THREE

**SANTEE SCHOOL DISTRICT**

**Bid #1920-001-077**

**Old Lockers/Shower Interior Demolition at Chet F. Harritt School Site**

<p>ADDENDUM NUMBER THREE</p> <p><b>SANTEE SCHOOL DISTRICT</b></p> <p><b>Bid #1920-001-077</b></p> <p><b>Old Lockers/Shower Interior Demolition at Chet F. Harritt School Site</b></p> <p>Page 1 of 1</p>
--